

DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

L.Dis.No.: 2070 / A /2026

Dated : 09/04/2026

Office of the DHO,
Kancheepuram.

SANITARY CERTIFICATE

(Under the Tamilnadu Education Rules)

APPENDIX-3 (Chapter III Rule 24)

(Issued to M/s.GRACE GLOBAL SCHOOL its premises of which is at Puthavedu Rod,
Moondramkattalai, Kundrathur, Chennai – 600 069, Kancheepuram District)

Period from 2026–2027


I hereby declare that I have inspected GRACE GLOBAL SCHOOL its premises of which is at Puthavedu Rod, Moondramkattalai, Kundrathur, Chennai – 600 069, Kancheepuram District Has been inspected on 07.04.2026 and found,

- ❖ That the accommodation provided for each of the several divisions is sufficient and it is properly ventilated and lighted
- ❖ That the building is maintained in substantial repair
- ❖ That is neat and clean
- ❖ That the supply of drinking water is wholesome and safe
- ❖ That the latrine and urinal arrangements are adequate for both sex and good
- ❖ That in all other necessary aspects the sanitation is good.
- ❖ That the building is rat proof and properly drainage
- ❖ Employees are provided with personal protective devices (PPD)
- ❖ First aid kit box is kept ready with drugs for use and maintained by a responsible person
- ❖ Sewage disposal pit (septic tank) etc.is maintained as per rules.
- ❖ That the liquid and solid wastages are disposed of in a sanitary manner as per BMW rules.
- ❖ That in all other necessary aspects the aspects the sanitation is good.

Conditions:

- ❖ The authority should follow the COVID-19 Rules like Social Distance, Wearing Face Mask, Provision of Hand Wash.
- ❖ The Authority should ban the Cigarette and other tobacco products in the campus and visible board to be displayed–COTP Act 2003.
- ❖ Child labour should not be engaged.
- ❖ If anyone suffering from fever, cold, cough and difficulty in breathing, it should be informed to the local health authority,
- ❖ Unnecessary containers or things should be disposed to frequently to avoid mosquito breeding for the prevention and control of vector borne diseases.
- ❖ The number of urinals/toilets should be increased according to staff 's strength.
- ❖ The certificate is valid for one year from the date of issue.

Counter Signed


DISTRICT HEALTH OFFICER
KANCHEEPURAM DISTRICT.


Block Health Supervisor
Govt.Primary Health Center
Ezhichur, Kundrathur Block,
Kancheepuram District.



CHENNAI METROPOLITAN WATER SUPPLY
AND SEWERAGE BOARD
WATER AND WASTE WATER TESTING LABORATORY
QUALITY ASSURANCE WING, No.1, NEW AVADI ROAD,
KILPAUK, CHENNAI - 600010.



ULR No : TC141662600001120F		TEST REPORT - DRINKING WATER		Doc.No: CMWSSB/FRM/7.8/01	
Report No:	TR/2026/1120-01	Report Issue Date:	23/07/2026	Page No	1 of 3
Challan No:	240	Challan Date:	20/07/2026	Amount (Rs)	2856/-

Client Name & Address
& Contact No / Email.ID :
Grace Global School,
Puthavedu Road, Moondram Kattalai,
Kundrathur,
Chennai - 69

Sample Name	Water	Sample Description	: Drinking water
Sample Number	: 1120	Sample Container	: Jerry Can
Sample Submitted by	: Customer	Location & Date	: Bore Well Water - 20/07/2026
Sample Quantity	: 2 Litres	Sample Condition	: Good
Sample Received On	: 20/07/2026	Environmental Condition	: 23.0°C - 27.0°C
Test Commenced on	: 20/07/2026	Test Completed on	: 21/07/2026

S. No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012	
					Acceptable Limit	Permissible Limit
1	Colour	CU	IS 3025: Part 4: 2021	2	5	15
2	Odour	--	IS 3025: Part 5: 2018	Agreeable	Agreeable	Agreeable
3	Turbidity	NTU	IS 3025: Part 10: 2023	1.9	1	5
4	pH @ 25°C	--	IS 3025: Part 11: 2022	7.27	6.5 To 8.5	6.5 To 8.5
5	Electrical Conductivity @25°C	µS/cm	IS 3025: Part 14: 2013(RA 2023)	2010	-	-
6	Total Dissolved Solids	mg/L	IS 3025: Part 16: 2023	1065	500	2000
7	Total Hardness as CaCO ₃	mg/L	IS 3025: Part 21: 2009(RA 2023)	683	200	600
8	Calcium as Ca	mg/L	IS 3025: Part 40: 2024	155	75	200
9	Magnesium as Mg	mg/L	IS 3025: Part 46: 2023	72	30	100
10	Chloride as Cl	mg/L	IS 3025: Part 32: 1988(RA 2019)	320	250	1000

---Contd---

[Signature]
23/07/26

Reviewed by
Water Analyst

[Signature]
23/07/26

Authorised Signatory
M.Sudha-Water Analyst

Note:

1. The test results relate only to the items tested. & The result applied to the sample as received basis.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.



CHENNAI METROPOLITAN WATER SUPPLY
AND SEWERAGE BOARD
WATER AND WASTE WATER TESTING LABORATORY
QUALITY ASSURANCE WING, No.1, NEW AVADI ROAD,
KILPAUK, CHENNAI - 600010.



ULR No : TC141662600001120F

TEST REPORT - DRINKING WATER

Doc.No: CMWSSB/FRM/7.8/01

Report No: TR/2026/1120-01

Report Issue Date: 23/07/2026

Page No 2 of 3

Challan No: 240

Challan Date: 20/07/2026

Amount (Rs) 2856/-

S. No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012	
					Acceptable Limit	Permissible Limit
11	Total alkalinity as CaCO ₃	mg/L	IS 3025: Part 23: 2023	420	200	600
12	Chlorine, Residual	mg/L	IS 3025: Part 26: 2021	BLQ(LOQ:0.2)	0.2	1.0
13	Ammonia as N	mg/L	IS 3025: Part 34: 1988(RA 2019)	BLQ(LOQ:0.1)	0.5	No Relaxation
14	Nitrite as NO ₂	mg/L	IS 3025: Part 34: 2019(RA 2019)	0.04	-	-
15	Fluoride as F	mg/L	IS 3025: Part 60: 2008(RA 2019)	BLQ(LOQ:0.2)	1.0	1.5
16	Sulphate as SO ₄	mg/L	IS 3025: Part 24: Sec 1: 2022	150	200	400
17	Iron as Fe	mg/L	IS 3025: Part 53: 2024	0.12	0.3	No Relaxation

--Contd---

[Signature]
23/07/26

Reviewed by
Water Analyst

[Signature]
23/07/26
Authorised Signatory
M.Sudha-Water Analyst

Note:

1. The test results relate only to the items tested. & The result applied to the sample as received basis.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.



CHENNAI METROPOLITAN WATER SUPPLY
AND SEWERAGE BOARD
WATER AND WASTE WATER TESTING LABORATORY
QUALITY ASSURANCE WING, No.1, NEW AVADI ROAD,
KILPAUK, CHENNAI - 600010.

TEST REPORT - DRINKING WATER

Doc.No: CMWSSB/FRM/7.8/01

Report No:	TR/2026/1120-02	Report Issue Date:	23/07/2026	Page No	3 of 3
Challan No:	240	Challan Date:	20/07/2026	Amount (Rs)	2856/-

Client Name & Address
& Contact No / Email.ID : Grace Global School,
Puthavedu Road, Moondram Kattalai,
Kundrathur,
Chennai - 69

Sample Name	Water	Sample Description	: Drinking water
Sample Number	: 1120	Sample Container	: Jerry Can
Sample Submitted by	: Customer	Location & Date	: Bore Well Water - 20/07/2026
Sample Quantity	: 2 Litres	Sample Condition	: Good
Sample Received On	: 20/07/2026	Environmental Condition	: 23.0°C - 27.0°C
Test Commenced on	: 20/07/2026	Test Completed on	: 21/07/2026

S. No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012	
					Acceptable Limit	Permissible Limit
18	Albuminoid Nitrogen	mg/L	CMWSSB SOP/001	0.096	-	-
19	Oxygen Absorbed @ 4 Hrs	mg/L	IS 3025: Part 63: 2007	1.05	-	-
20	Phosphate as P	mg/L	IS 3025: Part 31: Sec 1: 2022	0.03	-	-

BLQ: Below limit of Quantification LOQ: Limit of Quantification

Remarks:

The tested sample is not conformed to IS: 10500:2012 (RA: 2019) Drinking water specification with respect to above tested parameters.

J. R. R. R.
23/07/26

Reviewed by
Water Analyst

M. Sudha
23/07/26

Authorised Signatory
M.Sudha-Water Analyst

Note:

1. The test results relate only to the items tested. & The result applied to the sample as received basis.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.

-----End of Test Report-----